

## Flood Prone Land

### Land to which this control applies

Land identified as being affected by flooding on the [Flood Risk Precinct Maps](#), or as otherwise determined by Council.

### Uses to which this control applies

Land use groups are shown in Table 1, below the Development Control Matrix.

### Outcomes

- Protection of people.
- Protection of the natural environment.
- Protection of private and public infrastructure and assets.

### Requirements

1. Development must comply with the prescriptive controls set out in the Matrix below. Where a property is affected by more than one Flood Risk Precinct, or has varying Flood Life Hazard Category across it, the assessment must consider the controls relevant at each location on the property.
2. Development on flood prone land requires the preparation of a Flood Management Report by a suitably qualified professional.

### Notes:

*The purpose of this controls is to guide development in accordance with the objectives and processes set out in the NSW Government's Flood Prone Land Policy.*

*The Flood Management Report shall outline the identified flood risks relevant to the proposal, as well as address each of the relevant prescriptive controls with a thorough assessment to indicate the extent of compliance and appropriateness of the development.*

*A Section 88B notation under the Conveyancing Act 1919 may be placed on the title describing the location and type of flood risk mitigation works with a requirement for their retention and maintenance.*

### Links to further information:

[Guidelines for Development on Flood Prone Land](#)  
[Water Management Policy](#)  
[Floodplain Development Manual \(NSW Government, 2005\)](#)

### How to use this Matrix:

1. Determine whether your property is in a low, medium or high flood risk precinct using the [Flood Risk Precinct Maps](#)
2. Determine your land use (eg: Vulnerable & Critical Use, Residential Use) using Table 1.
3. Match your flood risk precinct and land use in the matrix to determine the controls that apply to your development. The controls are listed after the matrix.

### Matrix 1: Prescriptive Controls for Development on Flood Prone Land

		High Flood Risk Precinct				
		Vulnerable & Critical Use	Residential Use	Business & Industrial Use	Recreational & Environmental Use	Subdivision & Civil Works
<b>A</b>	<b>Flood effects caused by Development</b>	A1 A3	A1 A3	A1 A3	A1 A3	A1 A3

<b>B</b>	<b>Building Components &amp; Structural</b>	B1 B2 B3	B1 B2 B3	B1 B2 B3	B1 B2 B3	
<b>C</b>	<b>Floor Levels</b>	C2 C3	C1 C3 C6	C1 C3 C6 C7	C3	C5
<b>D</b>	<b>Car Parking</b>	D1 D2 D3 D4 D7	D1 D2 D3 D4 D5 D6	D1 D2 D3 D4 D5 D6	D1 D2 D3 D4 D5 D6	D1
<b>E</b>	<b>Emergency Response</b>	E1 E2	E1	E1	E1	E3
<b>F</b>	<b>Fencing</b>	F1	F1	F1	F1	F1
<b>G</b>	<b>Storage of Goods</b>	G1	G1	G1	G1	
<b>H</b>	<b>Pools</b>	H1	H1	H1	H1	H1

<b>Medium Flood Risk Precinct</b>						
		Vulnerable & Critical Use	Residential Use	Business & Industrial Use	Recreational & Environmental Use	Subdivision & Civil Works
<b>A</b>	<b>Flood effects caused by Development</b>	A2 A3	A2 A3	A2 A3	A2 A3	A2 A3
<b>B</b>	<b>Building Components &amp; Structural</b>	B1 B2 B3	B1 B2 B3	B1 B2 B3	B1 B2 B3	
<b>C</b>	<b>Floor Levels</b>	C2 C3	C1 C3 C4 C6	C1 C3 C4 C6 C7	C3	C5
<b>D</b>	<b>Car Parking</b>	D1 D2 D3 D4 D7	D1 D2 D3 D4 D5 D6	D1 D2 D3 D4 D5 D6	D1 D2 D3 D4 D5 D6	D1
<b>E</b>	<b>Emergency Response</b>	E1 E2	E1	E1	E1	E3
<b>F</b>	<b>Fencing</b>	F1	F1	F1	F1	F1
<b>G</b>	<b>Storage of Goods</b>	G1	G1	G1	G1	
<b>H</b>	<b>Pools</b>	H1	H1	H1	H1	H1

		<b>Low Flood Risk Precinct</b>				
		Vulnerable & Critical Use	Residential Use	Business & Industrial Use	Recreational & Environmental Use	Subdivision & Civil Works
<b>B</b>	<b>Building Components &amp; Structural</b>	B1 B2 B3				
<b>C</b>	<b>Floor Levels</b>	C2 C3				C5
<b>D</b>	<b>Car Parking</b>	D2 D7				
<b>E</b>	<b>Emergency Response</b>	E1 E2				E3

#### **A. FLOOD EFFECTS CAUSED BY DEVELOPMENT**

A1	Development shall not be approved unless it can be demonstrated in a Flood Management Report that it has been designed and can be constructed so that in all events up to the Probable Maximum Flood event: (a) There are no adverse impacts on flood levels or velocities caused by alterations to the flood conveyance; (b) There are no adverse impacts on surrounding properties; and (c) It is sited to minimise exposure to flood hazard.
A2	Development shall not be approved unless it can be demonstrated in a Flood Management Report that it has been designed and can be constructed so that in all events up to the 1% AEP event: (a) There are no adverse impacts on flood levels or velocities caused by alterations to the flood conveyance; (b) There are no adverse impacts on surrounding properties; and (c) It is sited to minimise exposure to flood hazard.
A3	Development shall not be approved unless it can be demonstrated in a Flood Management Report that in all events up to the 1% AEP event there is no net loss of flood storage.  If Compensatory Works are proposed to balance the loss of flood storage from the development, the Flood Management Report shall include detailed calculations to demonstrate how this is achieved.

#### **B. BUILDING COMPONENTS AND STRUCTURAL SOUNDNESS**

B1	All buildings shall be designed and constructed with flood compatible materials in accordance with "Reducing Vulnerability of Buildings to Flood Damage: Guidance on Building in Flood Prone Areas", Hawkesbury-Nepean Floodplain Management Steering Committee (2006).
B2	All new development must be designed and constructed to ensure structural integrity up to the Flood Planning Level in a 1% AEP flood event, taking into account the forces of floodwater, wave action, flowing water with debris, buoyancy and immersion. Where shelter-in-place refuge is required, the structural integrity for the refuge is to be up to the Probable Maximum Flood level. Structural certification shall be provided confirming the above.
B3	All new electrical equipment, power points, wiring, fuel lines, sewerage systems or any other service pipes and connections must be waterproofed and/or located above the Flood Planning Level. All existing electrical equipment and power points located below the Flood Planning Level within the subject structure must have residual current devices installed that turn off all electricity supply to the property when flood waters are detected.

#### **C. FLOOR LEVELS**

C1	New floor levels within the development shall be at or above the Flood Planning Level.
C2	All floor levels within the development shall be at or above the Probable Maximum Flood level or Flood Planning Level, whichever is higher.
C3	All new development must be designed and constructed so as not to impede the floodway or flood conveyance on the site, as well as ensuring no net loss of flood storage in all events up to the 1% AEP event.

	For suspended pier/pile footings: a) The underfloor area of the dwelling below the 1% AEP flood level is to be designed and constructed to allow clear passage of floodwaters, taking into account the potential for small openings to block; and (b) At least 50% of the perimeter of the underfloor area is of an open design from the natural ground level up to the 1% AEP flood level; and (c) No solid areas of the perimeter of the underfloor area would be permitted in a floodway
C4	A one-off addition or alteration below the Flood Planning Level of less than 30 square metres (in total, including walls) may be considered only where: (a) it is an extension to an existing room; and (b) the Flood Planning Level is incompatible with the floor levels of the existing room; and (c) out of the 30 square metres, not more than 10 square metres is below the 1% AEP flood level.  This control will not be permitted if this provision has previously been utilised since the making of this Plan.  The structure must be floodproofed to the Flood Planning Level, and the Flood Management Report must demonstrate that there is no net loss of flood storage in all events up to the 1% AEP event.
C5	The applicant must demonstrate that future development following a subdivision proposal can be undertaken in accordance with this Development Control Plan.
C6	Consideration may be given to the retention of an existing floor level below the Flood Planning Level when undertaking a first floor addition provided that: (a) it is not located within a floodway; and (b) the original foundations are sufficient to support the proposed final structure above them. The Flood Management Report must include photos and structural certification must be provided; and (c) none of the external walls of the existing structure are to be removed and replaced; and (d) the ground floor is dry floodproofed.
C7	Consideration may be given to a floor level below the Flood Planning Level within the first 5 metres from the street front in an existing business zone provided it can be demonstrated that: (a) The minimum floor level is no lower than the adjacent footpath level, and (b) The maximum internal distance from the front of the building is 5 metres, which can only apply to one side of an individual premises, and (c) The maximum area for the floor area to be below the Flood Planning Level for an individual premises is 30 square metres, and (d) There is direct internal access between areas above and below the Flood Planning Level for each individual premises

#### D. CAR PARKING

D1	Open carpark areas and carports shall not be located within a floodway.
D2	The lowest floor level of open carparks and carports shall be constructed no lower than the natural ground levels, unless it can be shown that the carpark or carport is free draining with a grade greater than 1% and that flood depths are not increased.
D3	Carports must be of open design, with at least 2 sides completely open such that flow is not obstructed up to the 1% AEP flood level. Otherwise it will be considered to be enclosed.  When undertaking a like-for-like replacement and the existing garage/carport is located on the street boundary and ramping is infeasible, consideration may be given for dry floodproofing up to the 1% AEP flood level.
D4	Where there is more than 300mm depth of flooding in a car park or carport during a 1% AEP flood event, vehicle barriers or restraints are to be provided to prevent floating vehicles leaving the site. Protection must be provided for all events up to the 1% AEP flood event
D5	Enclosed Garages must be located at or above the 1% AEP level
D6	All enclosed car parks (including basement carparks) must be protected from inundation up to the Flood Planning Level. All access, ventilation, driveway crests and any other potential water entry points to any enclosed car parking shall be above the Flood Planning Level.  Where a driveway is required to be raised it must be demonstrated that there is no net loss to available flood storage in any event up to the 1% AEP flood event and no impact on flood conveyance through the site.  Council will not accept any options that rely on electrical, mechanical or manual exclusion of the floodwaters from entering the enclosed carpark
D7	All enclosed car parks must be protected from inundation up to the Probable Maximum Flood level or Flood Planning Level whichever is higher. For example, basement carpark driveways must be provided with a crest at or above the relevant Probable Maximum Flood level or Flood Planning Level whichever is higher. All access, ventilation and any other potential water entry points to any enclosed car parking shall be at or above the relevant Probable Maximum Flood level or Flood Planning Level whichever is higher.

#### E. EMERGENCY RESPONSE

E1	<p>If the property is affected by a Flood Life Hazard Category of H3 or higher, then Control E1 applies and a Flood Emergency Assessment must be included in the Flood Management Report.</p> <p>If the property is affected by a Flood Life Hazard Category of H6, then development is not permitted unless it can be demonstrated to the satisfaction of the consent authority that the risk level on the property is or can be reduced to a level below H6 or its equivalent.</p> <p>If the property is flood affected but the Flood Life Hazard Category has not been mapped by Council, then calculations for its determination must be shown in the Flood Management Report, in accordance with the "Technical Flood Risk Management Guideline: Food Hazard", Australian Institute for Disaster Resilience (2012).</p> <p>Where flood-free evacuation above the Probable Maximum Flood level is not possible, new development must provide a shelter-in-place refuge where:</p> <ul style="list-style-type: none"> <li>a) The floor level is at or above the Probable Maximum Flood level; and</li> <li>b) The floor space provides at least 2m<sup>2</sup> per person where the flood duration is long (6 or more hours) in the Probable Maximum Flood event, or 1m<sup>2</sup> per person for less than 6 hours;</li> <li>c) It is intrinsically accessible to all people on the site, plainly evident, and self-directing, with sufficient capacity of access routes for all occupants without reliance on an elevator; and</li> <li>d) It must contain as a minimum: sufficient clean water for all occupants; portable radio with spare batteries; torch with spare batteries; and a first aid kit</li> </ul> <p>Class 10 classified buildings and structures (as defined in the Building Codes of Australia) are excluded from this control.</p> <p>In the case of change of use or internal alterations to an existing building, a variation to this control may be considered if justified appropriately by a suitably qualified professional.</p> <p>Note that in the event of a flood, occupants would be required to evacuate if ordered by Emergency Services personnel regardless of the availability of a shelter-in-place refuge.</p>
E2	<p>If a shelter-in-place refuge is required, it must contain as a minimum: sufficient clean water for all occupants; portable radio with spare batteries; torch with spare batteries; a first aid kit; emergency power; and a practical means of medical evacuation.</p>
E3	<p>It must be demonstrated that evacuation or a shelter-in-place refuge in accordance with the requirements of this DCP will be available for any potential development arising from a Torrens title subdivision.</p>

#### F. FENCING

F1	<p>Fencing, (including pool fencing, boundary fencing, balcony balustrades and accessway balustrades) shall be designed so as not to impede the flow of flood waters and not to increase flood affectation on surrounding land. At least 50% of the fence must be of an open design from the natural ground level up to the 1% AEP flood level. Less than 50% of the perimeter fence would be permitted to be solid. Openings should be a minimum of 75 mm x 75mm.</p>
----	--

#### G. STORAGE OF GOODS

G1	<p>Hazardous or potentially polluting materials shall not be stored below the Flood Planning Level unless adequately protected from floodwaters in accordance with industry standards.</p>
----	--

#### H. POOLS

H1	<p>Pools located within the 1% AEP flood extent are to be in-ground, with coping flush with natural ground level. Where it is not possible to have pool coping flush with natural ground level, it must be demonstrated that the development will result in no net loss of flood storage and no impact on flood conveyance on or from the site.</p> <p>All electrical equipment associated with the pool (including pool pumps) is to be waterproofed and/or located at or above the Flood Planning Level.</p> <p>All chemicals associated with the pool are to be stored at or above the Flood Planning Level.</p>
----	---



**Table 1: Land Use Groups**

<b>Vulnerable &amp; Critical</b>		
Child care centre	Home-based child care	Educational establishment
Hospital	Emergency services facility	Respite day care centre
Residential care facilities	Seniors housing	Group home
Tourist and visitor accommodation	Caravan park	Correctional centre
Electricity generating works	Public Utility Undertaking (SP2)	Telecommunications facility (SP2)

<b>Residential</b>		
Dwelling house	Secondary dwelling	Dual occupancy
Residential apartment building	Multi dwelling housing	Hostel or Boarding House
Attached dwelling	Semi-detached dwelling	Shop top housing
Exhibition home or village	Additions/alterations to residential dwelling	Development ancillary to residential development

<b>Business &amp; industrial</b>		
Business or office premises	Retail premises	Medical centre
Registered club	Entertainment or recreation facility	Community facility
Function centre	Public administration building	Storage premises
Eco-tourist facilities	Camping ground	Patient transport facilities
Place of public worship	Home business	Mortuary or crematorium
Veterinary hospital	Animal boarding establishment	Charter and tourism boating facility
Warehouse or distribution centre	Sex services premises	Service station
Advertising structure or Signage	Car park	Water recreation structure
General industry	Depot	Transport facility
Vehicle repair facility	Boat building and repair facility	Port, wharf or marina
Waste disposal facility	Waste water disposal system	Water supply system
Industrial training facility	Additions/alterations to business/industrial buildings	Occupation/change of use of an existing premises

<b>Recreational and Environmental</b>		
Boat shed	Recreation facility (outdoor)	Environmental facility
Flood mitigation works	Environment protection works	Buildings or structures for any kind of farming
Extractive industry		

<b>Subdivision</b>		
Subdivision	Earthworks	Demolition

<b>No Controls</b>		
Livestock agriculture	Agriculture	Jetty
Mooring & mooring pen	Subdivision of a sector, buffer area or development site in a release area	